

SUGGESTED SPECIFICATIONS



Series TCII™, Oil, Gas, Combination Gas/Oil Boiler-Burner Units

I. GENERAL REQUIREMENTS

- A. The boiler(s) shall be of a low pressure, cast iron, wet base, forced draft design and shall be tested and rated in accordance with the current edition of AHRI “Testing and Rating Standard for Heating Boilers”.
- B. The boiler(s) shall be listed in the AHRI Ratings Directory and shall be capable of developing full AHRI listed output at 100 percent firing rate.
- C. The boiler(s) will be Peerless® model _____ for (oil) (gas) (combination gas/oil) firing with a gross output of _____ MBH and net (water) (steam) rating of _____ MBH.
- D. The boiler(s) shall be constructed in accordance with the provisions of Section IV of the ASME Boiler and Pressure Vessel Code and shall be stamped with the required ASME symbol. Each boiler section shall be hydrostatically pressure tested for a maximum allowable working pressure of 80 PSIG for water and 15 PSIG for steam.
- E. The boiler(s) shall be field assembled and hydrostatically tested in accordance with the manufacturer’s installation instructions. All work shall be completed in a neat and workmanlike manner.
- F. *Optional Factory Assembled Sections:*
The boiler(s) shall be provided with factory assembled sections. The jacket, burner, trim and controls are to be provided separately. The sections shall be assembled with individual draw rods and graphite port connectors. High temperature sealing rope shall be used to provide a permanent gas-tight seal between the sections. The boiler(s) shall be hydrostatically tested in accordance with Section IV of the ASME Boiler and Pressure Vessel Code for a maximum allowable working pressure of 80 PSIG for water and 15 PSIG for steam.
- G. *Optional Factory Packaged Boilers:*
The boiler(s) shall be factory packaged with jacket, burner, trim and controls mounted and wired. The sections shall be assembled with individual draw rods and graphite port connectors. High temperature sealing rope shall be used to provide a permanent gas-tight seal between the sections. The boiler(s) shall be hydrostatically tested in accordance with Section IV of the ASME Boiler and Pressure Vessel Code for a maximum allowable working pressure of 80 PSIG for water and 15 PSIG for steam. The boiler(s) shall be fire-tested (optional) for a functional check of all components prior to shipment.
- H. The boiler(s) shall be CSA listed and bear the CSA marking on the boiler.

II. BOILER CONSTRUCTION FEATURES

- A. The boiler sections shall be assembled using individual draw rods between each section for ease of assembly and to evenly distribute tension between the sections.
- B. Each section shall be evenly spaced, and high temperature sealing rope shall be used to provide a permanent gas-tight seal between the sections.

- C. Graphite port connectors shall be used at each port opening to provide a permanent water-tight seal between the sections.
- D. The boiler(s) sections shall be of a wet base design to provide a complete water backed heating surface around the combustion chamber area for maximum heat transfer and low floor temperatures.
- E. The boiler(s) shall be furnished with side cleanout plates for ease of inspection and cleaning of the flueways. The cleanout plates shall be sealed to the boiler with high temperature sealing rope.
- F. The boiler(s) shall be furnished with an integral cast iron flue collector and a cast iron rear flue outlet.
- G. The boiler(s) shall be provided with an adjustable damper which is capable of being securely locked in position to pressurize the boiler for forced draft operation.
- H. The boiler(s) shall have no requirement for refractory chamber liner and target wall to protect the base of the firebox and the back section.
- I. The boiler(s) shall be provided with an insulated burner mounting plate with the necessary tappings for mounting the burner(s).
- J. The boiler(s) shall be provided with temperature resistant or Pyrex® glass front and rear flame observation ports to permit visual inspection of the burner flame.
- K. The boiler(s) shall be provided with an insulated steel flush jacket with a painted finish. The jacket shall be designed to permit installation after the supply and return piping is connected.
- L. The boiler(s) shall be furnished with steel angle rails to provide a level and smooth surface for ease of assembly.
- M. Boiler(s) for installation in a hot water heating system shall be provided with a Balanced Temperature Return component that is size-specific for each boiler model. The Balanced Temperature Return will provide even temperature distribution throughout the boiler.
- N. The boiler(s) shall be equipped with Flue Rod Baffles to maximize Thermal Efficiency.
- O. The boiler Front Section and Back Section shall have a machined flanged connection to fit a standard 10-inch 125# flange with an 8-1/2" bolt hole circle.

III. BOILER FOUNDATION

- A. A concrete housekeeping pad shall be provided as recommended by the boiler manufacturer if the boiler room floor is not level or if additional structural support is needed.

IV. INSPECTION TAPPINGS (OPTIONAL)

- A. The front, back and intermediate sections shall be provided with 1-1/2" NPT inspection tappings located on the bottom, right and left side and on the upper right side above the crown sheet. The tappings shall be plugged with (brass plugs) (nipples and caps).

V. TANKLESS WATER HEATERS (OPTIONAL)

- A. The boiler(s) shall be provided with (an) internal tankless water heater(s) rated at _____ GPM at a 40° F to 140° F temperature rise.
- B. The boiler(s) shall be provided with a low limit temperature control set to maintain a 200° F boiler water temperature.

VI. BOILER TRIM AND CONTROLS

For Water Boilers:

- A. The boiler(s) shall be provided with a safety relief valve set to relieve at (30) (50) (80) PSIG. The valve shall conform to Section IV of the ASME Boiler and Pressure Vessel Code.
- B. The boiler(s) shall be provided with a combination pressure-temperature gauge to indicate boiler pressure and temperature.
- C. The boiler(s) shall be provided with an operating temperature control and a manual reset high limit temperature control.
- D. The boiler(s) shall be provided with a (float type) (probe type) low water cut-off.

For Steam Boilers:

- A. The boiler(s) shall be provided with a safety valve set to relieve at 15 PSIG. The valve shall conform to Section IV of the ASME Boiler and Pressure Vessel Code.
- B. The boiler(s) shall be provided with a compound steam gauge to indicate boiler pressure.
- C. The boiler(s) shall be provided with a water gauge and gauge cocks.
- D. The boiler(s) shall be provided with an operating pressure control and a manual reset high limit pressure control.
- E. The boiler(s) shall be provided with a (float type) (probe type) low water cut-off.

VII. BAROMETRIC DRAFT DAMPER (required when excessive negative chimney draft exists)

- A. A barometric draft damper, of the double acting type, shall be installed for each boiler. The barometric damper shall be sized and installed in accordance with the boiler manufacturer's recommendations. Gas and combination gas/oil fired boilers shall have a thermal spill switch installed on each damper.

VIII. BURNER REQUIREMENTS

For #2 Oil Burners:

- A. The oil burner(s) shall be U.L. certified and of the flame retention, forced draft type capable of firing _____ GPH of No. 2 fuel oil.
- B. The burner motor electrical characteristics shall be _____ volts, 60 Hz, _____ phase.
- C. The control circuit electrical characteristics shall be 120 volts, 60 Hz, 1 phase.
- D. The burner(s) shall be (*specify manufacturer*) Model _____.
- E. The oil burner(s) shall be designed to operate at the rated input with 12.0% to 12.5% CO₂ and 0 to a trace of smoke when firing No. 2 fuel oil.

For Gas Burners:

- A. The gas burner(s) shall be U.L. certified and of the flame retention, forced draft type capable of firing _____ MBH of (natural) (LP) gas. The inlet gas pressure to the gas control train shall be _____" W.C. under full flow conditions.
- B. The burner motor electrical characteristics shall be _____ volts, 60 Hz, _____ phase.
- C. The control circuit electrical characteristics shall be 120 volts, 60 Hz, 1 phase. A step-down control circuit transformer shall be provided if the supply voltage is other than 120 volts, 60 Hz, 1 phase.
- D. The burner(s) shall be (*specify manufacturer*) Model _____.
- E. The gas burner(s) shall be designed to operate at the rated input with 9% to 10% CO₂ when firing natural gas.

For Combination Gas/#2 Oil Burners:

- A. The combination gas/oil burner(s) shall be U.L. certified and of the flame retention, forced draft type capable of firing _____ GPH of No. 2 fuel oil and _____ MBH of (natural) (LP) gas. The inlet gas pressure to the gas control train shall be _____" W.C. under full flow conditions.
- B. The burner motor electrical characteristics shall be _____ volts, 60 Hz, _____ phase.
- C. The control circuit electrical characteristics shall be 120 volts, 60 Hz, 1 phase. A step-down control circuit transformer shall be provided if the supply voltage is other than 120 volts, 60 Hz, 1 phase.
- D. The burner(s) shall be (*specify manufacturer*) Model _____.
- E. The combination gas/oil burner(s) shall be designed to operate at the rated input with 12% to 12.5% CO₂ and 0 to a trace of smoke when firing No. 2 fuel oil; and 9% to 10% CO₂ when firing natural gas.

IX. OPTIONAL BOILER CONTROLS (*specify as required)**

- A. The boiler control system(s) shall comply with the requirements of _____

**Specify the name of any code(s) to be complied with (FM, IRI, CSD-1, etc.). Refer to Burner Spec & Data Sheets and current Trade Price List for availability of optional controls.*